



SHOW CAUSE NOTICE

Gujarat Pollution Control Board
Paryavaran Bhavan, Sector-10/A,
Gandhinagar - 382010
23222756

PCB ID : 27833
Legal ID : 23378

ACT : Air , Water , Hazardous

Show Cause Notice DATE : 11/05/2016

WHEREAS, the Officials of the Gujarat Pollution Control Board (hereinafter referred to as the Board, in short), conducted inspection on 09/03/2016 in order to verify the statements made by you in your application for Consent to Operate under the Air , Water , Hazardous Act / to ascertain the Compliances of Conditions specified in Consent Order.

WHEREAS during the inspection it was observed that:-

Reason :

As per IR dated: 9/3/16, (1) during visit compartment-B1 &B2 of battery B are not working & compartment-C1 of battery C is also not working and same is found filled with sludge. (2) During visit it is observed that sludge carrying over from all the ETP units. (3) It is required to improve and upgrade the existing ETP operation system for effective reduction of pollutants and also effective chemical dosing required for improvement. (4) As per AR dated 9/3/16 COD is 719 mg/L in place of 500 mg/L. (

<input checked="" type="checkbox"/>	1	This indicates that you have failed to fulfill the conditions mentioned in the Consent Order. Consequently , you have rendered yourself liable to be prosecuted under the provisions of the above mentioned Sections-Acts.
-------------------------------------	---	--

NOW THEREFORE, in exercise of the powers vested with this Board

Under Section 33(A) read with section 25/26 of the Water(Prevention and Control of Pollution) Act, 1974

Under section 31(A) read with section 21 of the Air (Prevention and Control of Pollution) Act, 1981

Under Hazardous Waste (Management, Handling & Transboundary Movement) Rules 2008

notice is hereby served on you, to show cause within 15 days from the date of receipt of this show cause notice in view of the non compliance observed above and why legal action should not be initiated as per the provision of the Acts which may include rejection of your application and suspension/ closure of your unit.

**For and on behalf of
Gujarat Pollution Control Board**

D. M. Thaker.

D. M. Thaker, Unit Head

NO : SCN-355748 , 11/05/2016

Narmada Clean Tech Ltd (Old Name:Bharuch Eco Aqua Infrastructure Ltd. [fetc]),
AT: SURTI BHAGOL, UMARWADAROAD, NEAR GUJARAT GAS CO. LTD.,
ANKLESHWAR,
ANKLESHWAR.,
Dist : Ankleshwar, Tal : Ankleshwar, SIDC : Not In Gidc
Phone : -

COPY TO :-

The RO Head(P.C.B.), Ankleshwar

With a request to carryout monitoring and send the detailed I.R. & A.R. for the sample collected to this office immediately.