



# SHOW CAUSE NOTICE

Gujarat Pollution Control Board  
Paryavaran Bhavan, Sector-10/A,  
Gandhinagar - 382010  
23222756

PCB ID : 27833  
Legal ID : 25371

ACT : Air , Water , Hazardous

Show Cause Notice DATE : 23/08/2016

WHEREAS, the Officials of the Gujarat Pollution Control Board (hereinafter referred to as the Board, in short), conducted inspection on 21/04/2016 in order to verify the statements made by you in your application for Consent to Operate under the Air , Water , Hazardous Act / to ascertain the Compliances of Conditions specified in Consent Order.

WHEREAS during the inspection it was observed that:-

**Reason :**

- (1) Display on TOC analyzer and on panel shows different readings.
- (2) Compartment -C1 of battery C is also not working and same is found filled with about 5000 MT of sludge/slurry.
- (3) Separate flow meter is not provided on each bore well.
- (4) More than 1500 MT of sludge is also found stored in sludge storage yard and about 150 MT of sludge found stored on open sludge drying platforms.
- (5) AR shows COD: 725 mg/L & BOD: 48 mg/L which is more than norms given in consent.

<input checked="" type="checkbox"/>	1	This indicates that you have failed to fulfill the conditions mentioned in the Consent Order. Consequently , you have rendered yourself liable to be prosecuted under the provisions of the above mentioned Sections-Acts.
-------------------------------------	---	--

NOW THEREFORE, in exercise of the powers vested with this Board  
Under Section 33(A) read with section 25/26 of the Water(Prevention and Control of Pollution) Act, 1974  
Under section 31(A) read with section 21 of the Air (Prevention and Control of Pollution) Act, 1981  
Under Hazardous Waste (Management, Handling & Transboundary Movement) Rules 2008  
notice is hereby served on you, to show cause within 15 days from the date of receipt of this show cause notice in view of the non compliance observed above and why legal action should not be initiated as per the provision of the Acts which may include rejection of your application and suspension/ closure of your unit.

**For and on behalf of  
Gujarat Pollution Control Board**

D. M. Thaker.

**D. M. Thaker, Unit Head**

**NO : SCN-367173 , 23/08/2016**

Narmada Clean Tech Ltd (Old Name:Bharuch Eco Aqua Infrastructure Ltd. [fetp]),  
AT: SURTI BHAGOL, UMARWADAROAD, NEAR GUJARAT GAS CO. LTD.,  
ANKLESHWAR,  
ANKLESHWAR.,  
Dist : Ankleshwar, Tal : Ankleshwar, SIDC : Not In Gidc  
Phone : -

COPY TO :-

The RO Head(P.C.B.), Ankleshwar

With a request to carryout monitoring and send the detailed I.R. & A.R. for the sample collected to this office immediately.